

# **HYDRO UNIT P**

# Air-to-Water rotary heat pump





### **TECHNICAL DATASHEET FOR MEDIUM TEMPERATURE SPACE HEATER**

Information requirements pursuant to regulation (EU) N°813/2013

#### Description

Model	HYDRO UNIT P 012
Air-to-Water Heat pump	Yes
Water-to-Water Heat pump	No
Brine-to-Water Heat pump	No
Low-temperature Heat pump (30°C / 35°C)	No
Equipped with supplementary heater	No
Heat pump combination heater	No
Climate	Average

#### Performances established in accordance with EN14511:2018 and EN14825:2018

Symbol Uı	٦	ĺ	
-----------	---	---	--

Rated heat output(*)	Prated	kW	9
Seasonal Space Heating Energy Efficiency	ηs,h	%	131
Annual energy consumption	QHE	kWh	5743

## Declared capacity (Pdh), declared coefficient of performance (COPd) and declared degradation coefficient (Cdh<sup>(\*\*)</sup>) for heating for part load at indoor temperature 20 °C and outdoor temperature Tj

ioda de indoor temperature 20 °C ana ot	ataoor temperatar		
	Pdh	kW	8.25
Tj = -7 °C	COPd		1.97
	Cdh(**)		-
	Pdh	kW	4.78
Tj = 2 °C	COPd		3.17
	Cdh(**)		-
	Pdh	kW	2.99
Tj = 7 °C	COPd		4.76
	Cdh(**)		0.98
	Pdh	kW	3.52
Tj = 12 °C	COPd		6.45
	Cdh(**)		0.97
	Pdh	kW	7.65
Tj = operation limit temperature °C	COPd		1.75
	Cdh(**)		-
Tj = bivalent temperature °C	Pdh	kW	8.25
	COPd		1.97
	Cdh(**)		•
Bivalent temperature	Tbiv	°C	-7
Operation limit temperature	TOL	°C	-10
Heating water operating limit	WTOL	°C	75

#### Power consumption in modes other than active mode

Off mode	POFF	W	10
Thermostat off-mode	PTO	W	15
Standby mode	PSB	W	10
Crankcase heater mode	PCK	W	0

### Supplementary heater

Rated heat output(*)	Psup	kW	0
Type of energy input			Electrical

#### Other items

Capacity control			VARIABLE
Outlet temperature control			VARIABLE
Water flow rate control			FIXED
Rated water flow rate outdoor exchanger(1)		m3/h	1800
Sound power level	LwA	dBA	54

Contact details	CARRIER SCS - Route de Thil - 01120 Montluel - FRANCE

<sup>(1)</sup>Not applicable for water-to-water and brine-to-water heat pumps

<sup>(\*)</sup>For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load f or heating Pdesignh, and the rated heat output of a supplementary heater sup is equal to the supplementary capacity for heating sup(Tj).

<sup>(\*\*)</sup>If Cdh is not determined by measurement then the default degradation coefficient of chillers shall be 0.9.