

# Sertifikat Certificate

## SERTIFIKAT O PREGLEDU TIPA /

TYPE EXAMINATION CERTIFICATE

T 2506

strana / page 1/2

Izdavač sertifikata delujući u okviru svog područja imenovanja i akreditacije, potvrđuje da je identifikovani tip proizvoda vrednovan u odnosu na odredbe iz Pravilnika o aparatima na gasovita goriva - Sl. glasnik RS 60/2023 i da zadovoljava primenljive zahteve za Modul B, za sledeće proizvode / The issuer of the certificate, acting within the framework of its designation and accreditation, confirms that the identified type of product has been evaluated in relation to the provisions of the Ordinance on gas fuel appliances - Sl. gazette RS 60/2023 and that it meets the applicable requirements for Module B, for the following products:

Na zahtev naručioca /  
by the request of purchaser

PMN d.o.o. Jagodinska 2 Beograd, Srbija / Serbia

Preduzeto je/  
has been undertaken:

Sertifikacija gasnog kondenzacionog kotla / Certification of gas  
condensing boiler

Proizveden od /  
manufactured by:

RUG Riello Urządzenia Grzewcze S.A. Kociwska 28, 87-100  
Toruń, Poljska/ Poland

Model/ model:

Beretta Power EVO - X ...  
vrsta/type: B23, B23P, C13, C33, C43, C53, C63, C83, C93, C13X,  
C33X, C43X, C53X, C63X, C83X, C93X kategorija/category: II<sub>2H3P</sub>

Trgovačka oznaka /  
trademark:

Beretta Power EVO - X ...

Izveštaj o vrednovanju /  
Valuation report:

Broj / No:

T 2506

Sa dokumentima u prilogu /  
with attached documents

videti Prilog A sertifikatu o pregledu tipa / see Annex A to the  
type examination certificate

Uslovi važenja i  
ograničenja / Validity  
conditions and limitations:

Važnost sertifikata je 10 godina od datuma izdavanja i može biti obnovljen na zahtev. Na osnovu ovog sertifikata se ne postavlja srpski znak usaglašenosti. Srpski znak usaglašenosti se može postaviti jedino uz sprovedeno ocenjivanje usaglašenosti sa primenom drugog modula prema Pravilniku o aparatima na gasovita goriva - Sl. glasnik RS 60/2023 / The certificate is valid for 10 years from the date of issue and can be renewed upon request. The Serbian mark of conformity is not placed on the basis of this certificate. The Serbian mark of conformity can only be placed after the evaluation of conformity with the application of the second module according to the Ordinance on Gas Fuel Appliances - Sl. gazette RS 60/2023

U slučaju modifikacija – izmena na proizvodu kojima se utiče na usaglašenost proizvoda, ovaj sertifikat se smatra nevažećim i proizvođač snosi posledice u slučaju njegove primene na tako izmenjene proizvode / In the case of modifications - changes to the product that affect the conformity of the product, this certificate is considered invalid and the manufacturer bears the consequences in case of its application to such modified products

Sertifikacija sprovedena / Evaluation performed from 15. 01. 2025. - 15.02.2025

Datum prve sertifikacije / Date of first certification:  
15.02.2025

Datum prethodnog izdanja / Date of previous  
issue:

Datum trenutnog izdanja / Current issue date:  
15.02.2025

Datum prestanka važenja / Expiry date / :  
14.02.2035




TEHNIČKI RUKOVODILAC SERTIFIKACIONOG  
TELA ZA PROIZVODE

Kristina Petković dipl.maš.inž.

Zabranjeno je umnožavanje izveštaja o vrednovanju i prezentacija rezultata vrednovanja bez prethodno pribavljene saglasnosti IMP- CGT Sertifikacionog tela za proizvode ili klijenta. Provera validnosti izveštaja se vrši putem elektronske pošte. Na izveštaj o vrednovanju i pripadajući sertifikat se može izjaviti prigovor/zalba prema propisanoj proceduri.

INSTITUT MIHAJLO PUPIN DOO BEOGRAD; Volgina 15, 11000, BEOGRAD-ZVEZDARA, Srbija; Matični broj 07014694; PIB 100008310  
CENTAR ZA GASNU TEHNIKU • SERTIFIKACIONO TELU ZA PROIZVODE • Telefon: +381 11 6772-151 • e-pošta: impcgt@pupin.rs



**PRILOG A SERTIFIKATU O PREGLEDU TIPRA BROJ /**

**TYPE EXAMINATION CERTIFICATE №**

**T 2506**

strana / page 2/2

Datum prvog izdanja / Date of first certification: 15.02.2025

Datum tekuće izdanje / Current issue date: 15.02.2025

Datum prethodnog izdanje / Date of previous issue: -

Naziv predmeta sertifikacije / Name of the certification subject:

**Gasni kondenzacioni kotao / Gas condensing boiler**

Proizvođač / Manufacturer:

**RUG Riello Urządzenia Grzewcze S.A. Kociewska 28, 87-100 Toruń, Poljska / Poland**

Tip / Type:

**Beretta Power EVO - X ...**

Primenjeni standardi / Applied standards:

**SRPS EN 15502-2-1, SRPS EN 15502-1**

Izveštaj o ispitivanju / Test report

**2005430/1 KIWA**

Sa dokumentacijom u prilogu / With documentation attached:

- Uputstvo za instaliranje, i korisnika / Installation, and User manual
- Dokumentacija ugrađenih komponenti / Documentation of embedded components
- Izveštaj o vrednovanju tipa T 2506 sa priložima / Evaluation report of type T 2506 with attachments

Detaljne tehničke karakteristike / Detailed technical characteristics

detaljno oznaka - tip - serija / mark - type - series specification :	tehničke karakteristike / technical characteristics :	kratak opis / short description :
<b>Beretta Power EVO - X ...</b>		
... 50 DEP	Q <sub>n</sub> = 5,2 ÷ 34,9 kW P <sub>n</sub> = 4,98 ÷ 33,99 kW* P <sub>n</sub> = 5,57 ÷ 37,31 kW**	samo za grejanje i mogućnost tople sanitarne vode preko posebnog rezervoara (nije u sklopu kotla) / only for heating and the possibility of domestic hot water through the external tank (out of the boiler)
... 50	Q <sub>n</sub> = 5,2 ÷ 45,0 kW P <sub>n</sub> = 4,98 ÷ 43,88 kW* P <sub>n</sub> = 5,57 ÷ 47,30 kW**	
... 65	Q <sub>n</sub> = 8,2 ÷ 55,0 kW P <sub>n</sub> = 7,87 ÷ 53,60 kW* P <sub>n</sub> = 8,78 ÷ 58,25 kW**	
... 80	Q <sub>n</sub> = 8,2 ÷ 70,0 kW P <sub>n</sub> = 7,87 ÷ 68,24 kW* P <sub>n</sub> = 8,78 ÷ 74,19 kW**	

napomene/notes

\* za 80/60°C / for 80/60 °C

\*\* za 50/30°C / for 50/30 °C



**Bilo kakve promene na uređaju moraju se prijaviti izdavaocu ove isprave. /**  
*Any changes on the device must be reported to the issuer of this document*