

Number	KIP-07868	Replaces	KIP-17568
Issue date	23-04-2025	Contract number	I 7230
Due date	22-04-2035	Scope	(EU) 2016/426 (9 March 2016)
Report number	2011765/4	Module	B (Type testing)
PIN	0476DN1765		

EU TYPE-EXAMINATION CERTIFICATE (GAR)

Kiwa Cermet Italia declares that the central heating condensing boiler, type(s):

MYNUTE EVO X 25C, MYNUTE EVO X 20R, EXCLUSIVE EVO X 25C, EXCLUSIVE EVO X 25R, MYNUTE EVO X 30C, MYNUTE EVO X 30R, EXCLUSIVE EVO X 30C, MYNUTE EVO X 35C, EXCLUSIVE EVO X 35C, EXCLUSIVE EVO X 35R, MYNUTE BOILER EVO X 25B, MYNUTE BOILER EVO X 35B

Manufacturer

RIELLO S.p.A.
Via Ing. Pilade Riello, 7
37045 Legnago (VR) - Italy

Meet the essential requirements as described in the
Regulation (EU) 2016/426 relating to appliances burning gaseous fuels.

Reference standard: EN 15502-1:2021+A1:2023, EN 15502-2-1:2022+A1:2023

This certificate is only valid in combination with the appendix to this certificate, where specific information and/or conditions are given.

Industry Division Manager
Maurizio Lorenzon

Kiwa Cermet Italia S.p.A.
Società con socio unico, soggetta
all'attività di direzione e
coordinamento di Kiwa Italia
Holding Srl

Via Cadriano, 23
40057 Granarolo dell'Emilia (BO)

Unità locale

Via Treviso 32/34
31020 San Vendemiano (TV)
Tel +39. 0438 411755

Fax +39.0438 22428

E-mail: info@kiwacermet.it

www.kiwa.it

Organismo Notificato n. 0476
Notified Body nr. 0476



PRD N° 0069PRD

Membro degli Accordi di Mutuo Riconoscimento EA, IAF e ILAC
Signatory of EA, IAF and ILAC Mutual Recognition Agreements

Number	KIP-07868	Page	1 of 2
Issue date	23-04-2025	Scope	(EU) 2016/426 (9 March 2016)
Due date	22-04-2035	Module	B (Type testing)
Report number	2011765/4		
PIN	0476DN1765		

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (GAR)

Brand name: **BERETTA**

Types:

Model name	Nominal Heat Input - Qmax (Hi)	
	CH	DHW
	(kW)	(kW)
MYNUTE EVO X 20R	20,0	20,0
MYNUTE EVO X 25C	20,0	25,0
EXCLUSIVE EVO X 25C	20,0	25,0
EXCLUSIVE EVO X 25R	20,0	25,0
MYNUTE BOILER EVO X 25B	20,0	25,0
MYNUTE EVO X 30C	25,0	30,0
EXCLUSIVE EVO X 30C	25,0	30,0
MYNUTE EVO X 30R	30,0	34,9
MYNUTE EVO X 35C	30,0	34,9
MYNUTE BOILER EVO X 35B	30,0	34,9
EXCLUSIVE EVO X 35C	32,0	34,9
EXCLUSIVE EVO X 35R	32,0	34,9

Appliance types:

B_{23P}, B_{53P}, C₁₃, C₃₃, C₄₃, C₅₃, C₆₃, C₈₃, C₉₃

C_{13x}, C_{33x}, C_{43x}, C_{53x}, C_{63x}, C_{83x}, C_{93x}

C₍₁₀₎₃^{*}

* : Installation valid only for gas groups H and E

Countries:

AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GR, HR, HU, IE, IT, LT, LU, LV, MT, NO, NL, PL, PT, RO, SE, SI, SK, TR

Number	KIP-07868	Page	2 of 2
Issue date	23-04-2025	Scope	(EU) 2016/426 (9 March 2016)
Due date	22-04-2035	Module	B (Type testing)
Report number	2011765/4		
PIN	0476DN1765		

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (GAR)

Gas groups:


Models		MYNUTE EVO X 25C, MYNUTE EVO X 20R, EXCLUSIVE EVO X 25C, EXCLUSIVE EVO X 25R, MYNUTE EVO X 30C, MYNUTE EVO X 30R, EXCLUSIVE EVO X 30C, MYNUTE EVO X 35C, EXCLUSIVE EVO X 35C, EXCLUSIVE EVO X 35R, MYNUTE BOILER EVO X 25B, MYNUTE BOILER EVO X 35B
Gas groups	mbar	
EY20	20	X
HY20	20;25	X
E	20	X
H	20;25	X
LL	20	X
Lw	20	X
Ls	13	X
M	20	X
P	30; 37; 50	X

The above gas groups can be combined according to the standard EN437:2021 and national situation of countries.

Note: Suffix "Y20" means that the appliances are suitable for the use of natural gas of the indicated gas group, mixed with hydrogen resulting in a gas mixture containing up to 20% of Hydrogen gas (H₂) when the appliance is set for the reference gas G20.

Remarks:

The validity of this certificate can be verified on request at the following e-mail address: info@kiwacermet.it
 This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia.
 Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.



Number	KIP-08066	Replaces	KIP-07869
Issue date	02-09-2025	Contract number	I 7230
Report number	2011765/5	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
PIN	0476DN1765	Module	B (Type testing)

EC TYPE-EXAMINATION CERTIFICATE (BED/R813)

Kiwa Cermet Italia, notified body for council Directive 92/42/EC, hereby declares that the Central heating condensing boilers, type(s):

MYNUTE EVO X 25C, MYNUTE EVO X 20R, EXCLUSIVE EVO X 25C, EXCLUSIVE EVO X 25R, MYNUTE EVO X 30C, MYNUTE EVO X 30R, EXCLUSIVE EVO X 30C, MYNUTE EVO X 35C, EXCLUSIVE EVO X 35C, EXCLUSIVE EVO X 35R, MYNUTE BOILER EVO X 25B, MYNUTE BOILER EVO X 35B

Manufacturer

RIELLO S.p.A.
Via Ing. Pilade Riello, 7
37045 Legnago (VR) - Italy

meet the requirements regarding useful efficiencies according to **article 4 of commission regulation (EU) No. 813/2013** and as described in the **Directive 92/42/EEC on efficiency requirements**.

Reference standard: EN 15502-1:2021+A1:2023, EN 15502-2-1:2022+A1:2023

This certificate is only valid in combination with the appendix to this certificate, where specific information and/or conditions are given.

Kiwa Cermet Italia S.p.A.
Società con socio unico, soggetta
all'attività di direzione e coordinamento
di Kiwa Italia Holding Srl

Via Cadriano, 23
40057 Granarolo dell'Emilia (BO)

Unità locale
Via Treviso 32/34
31020 San Vendemiano (TV)
Tel +39. 0438 411755
Fax +39.0438 22428

E-mail: info@kivacermet.it
www.kiwa.it

Organismo Notificato n. 0476
Notified Body nr. 0476

Industry Division Manager
Maurizio Lorenzon



PRD N° 0069PRD

Membro degli Accordi di Mutuo Riconoscimento EA, IAF e ILAC
Signatory of EA, IAF and ILAC Mutual Recognition Agreements

CERTIFICATE

Number	KIP-08066	Page	1 of 7
Issue date	02-09-2025	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
Report number	2011765/5	Module	B (Type testing)
PIN	0476DN1765		

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:
BERETTA

Specifications:
Model(s):
MYNUTE EVO X 20R, EXCLUSIVE EVO X 25R

Condensing boiler:		yes
Range rated:	yes	
Low-temperature boiler:		no
B1 boiler:	no	
Combination heater:	no ⁽¹⁾	

⁽¹⁾ The boiler can be connected to an external tank for domestic hot water production

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P ₄	19,5	kW
At 30 % of rated heat output and low-temperature regime (**)	P ₁	6,6	kW
Useful efficiencies (GCV)			
At rated heat output and high-temperature regime (*)	η ₄	88,2	%
At 30 % of rated heat output and low-temperature regime (**)	η ₁	98,9	%
Useful efficiencies (NCV)			
At rated heat output and high-temperature regime (*)	η ₁₀₀	97,9	%
At 30 % of rated heat output and low-temperature regime (**)	η ₃₀	109,8	%

(*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

(GCV) Calculated values are based on Gross calorific value (reference conditions:15 °C, 1013,25 mbar)

(NCV) Calculated values are based on Net calorific value (reference conditions:15 °C, 1013,25 mbar)

Efficiency's values have been measured with G20

The validity of this certificate can be verified on request at the following e-mail address: info@kiwacermet.it
This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia.
Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.

Number	KIP-08066	Page	2 of 7
Issue date	02-09-2025	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
Report number	2011765/5	Module	B (Type testing)
PIN	0476DN1765		

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:
BERETTA

Specifications:
Model(s):
MYNUTE EVO X 25C, EXCLUSIVE EVO X 25C, MYNUTE BOILER EVO X 25B

Condensing boiler:		yes
Range rated:	yes	
Low-temperature boiler:		no
B1 boiler:	no	
Combination heater:	yes	

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P ₄	19,5	kW
At 30 % of rated heat output and low-temperature regime (**)	P ₁	6,6	kW
Useful efficiencies (GCV)			
At rated heat output and high-temperature regime (*)	η ₄	88,2	%
At 30 % of rated heat output and low-temperature regime (**)	η ₁	98,9	%
Useful efficiencies (NCV)			
At rated heat output and high-temperature regime (*)	η ₁₀₀	97,9	%
At 30 % of rated heat output and low-temperature regime (**)	η ₃₀	109,8	%

(*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

(GCV) Calculated values are based on Gross calorific value (reference conditions:15 °C, 1013,25 mbar)

(NCV) Calculated values are based on Net calorific value (reference conditions:15 °C, 1013,25 mbar)

Efficiency's values have been measured with G20

The validity of this certificate can be verified on request at the following e-mail address: info@kiwacermet.it
This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia.
Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.

Number	KIP-08066	Page	3 of 7
Issue date	02-09-2025	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
Report number	2011765/5	Module	B (Type testing)
PIN	0476DN1765		

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:
BERETTA

Specifications:
Model(s):
MYNUTE EVO X 30C, EXCLUSIVE EVO X 30C

Condensing boiler:	yes
Range rated:	yes
Low-temperature boiler:	no
B1 boiler:	no
Combination heater:	yes

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P ₄	24,4	kW
At 30 % of rated heat output and low-temperature regime (**)	P ₁	8,2	kW
Useful efficiencies (GCV)			
At rated heat output and high-temperature regime (*)	η ₄	88,5	%
At 30 % of rated heat output and low-temperature regime (**)	η ₁	98,6	%
Useful efficiencies (NCV)			
At rated heat output and high-temperature regime (*)	η ₁₀₀	98,3	%
At 30 % of rated heat output and low-temperature regime (**)	η ₃₀	109,5	%

- (*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.
- (**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).
- (GCV) Calculated values are based on Gross calorific value (reference conditions:15 °C, 1013,25 mbar)
- (NCV) Calculated values are based on Net calorific value (reference conditions:15 °C, 1013,25 mbar)

Efficiency's values have been measured with G20

The validity of this certificate can be verified on request at the following e-mail address: info@kiwacermet.it
This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia.
Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.

Number	KIP-08066	Page	4 of 7
Issue date	02-09-2025	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
Report number	2011765/5	Module	B (Type testing)
PIN	0476DN1765		

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:
BERETTA

Specifications:
Model(s):
MYNUTE EVO X 30R

Condensing boiler:	yes
Range rated:	yes
Low-temperature boiler:	no
B1 boiler:	no
Combination heater:	no ⁽¹⁾

⁽¹⁾ The boiler can be connected to an external tank for domestic hot water production

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P ₄	29,3	kW
At 30 % of rated heat output and low-temperature regime (**)	P ₁	9,9	kW
Useful efficiencies (GCV)			
At rated heat output and high-temperature regime (*)	η_4	88,3	%
At 30 % of rated heat output and low-temperature regime (**)	η_1	98,8	%
Useful efficiencies (NCV)			
At rated heat output and high-temperature regime (*)	η_{100}	98,0	%
At 30 % of rated heat output and low-temperature regime (**)	η_{30}	109,7	%

(*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

(GCV) Calculated values are based on Gross calorific value (reference conditions:15 °C, 1013,25 mbar)

(NCV) Calculated values are based on Net calorific value (reference conditions:15 °C, 1013,25 mbar)

Efficiency's values have been measured with G20

The validity of this certificate can be verified on request at the following e-mail address: info@kiwacermet.it
This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia.
Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.

Number	KIP-08066	Page	5 of 7
Issue date	02-09-2025	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
Report number	2011765/5	Module	B (Type testing)
PIN	0476DN1765		

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:
BERETTA

Specifications:
Model(s):
MYNUTE EVO X 35C, MYNUTE BOILER EVO X 35B

Condensing boiler:	yes
Range rated:	yes
Low-temperature boiler:	no
B1 boiler:	no
Combination heater:	yes

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P ₄	29,3	kW
At 30 % of rated heat output and low-temperature regime (**)	P ₁	9,9	kW
Useful efficiencies (GCV)			
At rated heat output and high-temperature regime (*)	η ₄	88,3	%
At 30 % of rated heat output and low-temperature regime (**)	η ₁	98,8	%
Useful efficiencies (NCV)			
At rated heat output and high-temperature regime (*)	η ₁₀₀	98,0	%
At 30 % of rated heat output and low-temperature regime (**)	η ₃₀	109,7	%

- (*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.
- (**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).
- (GCV) Calculated values are based on Gross calorific value (reference conditions:15 °C, 1013,25 mbar)
- (NCV) Calculated values are based on Net calorific value (reference conditions:15 °C, 1013,25 mbar)

Efficiency's values have been measured with G20

The validity of this certificate can be verified on request at the following e-mail address: info@kiwacermet.it
This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia.
Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.

Number	KIP-08066	Page	6 of 7
Issue date	02-09-2025	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
Report number	2011765/5	Module	B (Type testing)
PIN	0476DN1765		

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:
BERETTA

Specifications:
Model(s):
EXCLUSIVE EVO X 35C

Condensing boiler:		yes
Range rated:	yes	
Low-temperature boiler:		no
B1 boiler:	no	
Combination heater:	yes	

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P ₄	31,2	kW
At 30 % of rated heat output and low-temperature regime (**)	P ₁	10,5	kW
Useful efficiencies (GCV)			
At rated heat output and high-temperature regime (*)	η ₄	88,5	%
At 30 % of rated heat output and low-temperature regime (**)	η ₁	98,8	%
Useful efficiencies (NCV)			
At rated heat output and high-temperature regime (*)	η ₁₀₀	98,3	%
At 30 % of rated heat output and low-temperature regime (**)	η ₃₀	109,7	%

- (*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.
- (**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).
- (GCV) Calculated values are based on Gross calorific value (reference conditions:15 °C, 1013,25 mbar)
- (NCV) Calculated values are based on Net calorific value (reference conditions:15 °C, 1013,25 mbar)

Efficiency's values have been measured with G20

The validity of this certificate can be verified on request at the following e-mail address: info@kiwacermet.it
This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia.
Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.

Number	KIP-08066	Page	7 of 7
Issue date	02-09-2025	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
Report number	2011765/5	Module	B (Type testing)
PIN	0476DN1765		

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:
BERETTA

Specifications:
Model(s):
EXCLUSIVE EVO X 35R

Condensing boiler:		yes
Range rated:	yes	
Low-temperature boiler:		no
B1 boiler:	no	
Combination heater:	no ⁽¹⁾	

⁽¹⁾ The boiler can be connected to an external tank for domestic hot water production

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P ₄	31,2	kW
At 30 % of rated heat output and low-temperature regime (**)	P ₁	10,5	kW
Useful efficiencies (GCV)			
At rated heat output and high-temperature regime (*)	η ₄	88,5	%
At 30 % of rated heat output and low-temperature regime (**)	η ₁	98,8	%
Useful efficiencies (NCV)			
At rated heat output and high-temperature regime (*)	η ₁₀₀	98,3	%
At 30 % of rated heat output and low-temperature regime (**)	η ₃₀	109,7	%

(*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

(GCV) Calculated values are based on Gross calorific value (reference conditions:15 °C, 1013,25 mbar)

(NCV) Calculated values are based on Net calorific value (reference conditions:15 °C, 1013,25 mbar)

Efficiency's values have been measured with G20

The validity of this certificate can be verified on request at the following e-mail address: info@kiwacermet.it
This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia.
Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.