

Certificate KIP-08344



Issue date	30-07-2026	Replaces	--
PIN	0476DR4719	Report number	2014719
Valid from	30-07-2026	Due date	29-07-2036
Module	B (Type testing)	Scope	Reg. (EU) 2016/426 (9 March 2016)

EU TYPE-EXAMINATION CERTIFICATE (GAR)

Kiwa Cermet Italia declares that the Central heating condensing boiler, type(s):

CIAO X 25C C10

Manufacturer

RIELLO S.p.A.
Via Ing. Pilade Riello, 7
37045 Legnago (VR) - Italy

Meet the essential requirements as described in the
Regulation (EU) 2016/426 relating to appliances burning gaseous fuels.

Reference standard:
EN 15502-1:2021+A1:2023,
EN 15502-2-1:2022+A1:2023/AC:2024,
CEN/TS 15502-3-1:2024

This certificate is only valid in combination with the appendix to this certificate, where specific information and/or conditions are given.

Kiwa Cermet Italia S.p.a.
Product Certification and Testing Director
Luigi Rindone



Certificate

KIP-08344

Issue date	30-07-2026	Replaces	--
PIN	0476DR4719	Report number	2014719
Valid from	30-07-2026	Due date	29-07-2036
Module	B (Type testing)	Scope	Reg. (EU) 2016/426 (9 March 2016)

APPENDIX TO EU TYPE- EXAMINATION CERTIFICATE (GAR)

Brand name:

BERETTA

Model name	Nominal heat input (Hi) Q _{max} - Q _{min} (kW)	
	CH	DHW
CIAO X 25C C10	20,0 – 2,0	25,0 – 5,0

Appliance types:

C₁₃, C₃₃, C₄₃, C₅₃, C₆₃, C₈₃, C₉₃, C₍₁₀₎₃

C_{13X}, C_{33X}, C_{43X}, C_{53X}, C_{63X}, C_{83X}, C_{93X}

Countries:

AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GR, HR, HU, IE, IT, LT, LU, LV, MT, NO, NL, PL, PT, RO, SE, SI, SK, TR

Gas groups:

Group	mbar	Group	mbar
H	20;25	HY20	20;25
E	20	EY20	20

The above gas groups can be combined according to the standard EN437:2021 and national situation of countries.

Note: Suffix "Y20" means that the appliances are suitable for the use of natural gas of the indicated gas group, mixed with hydrogen resulting in a gas mixture containing up to 20% of Hydrogen gas (H₂) when the appliance is set for the reference gas G20.

Remarks:

The declared nominal heat input values, are referred to gas G20.

The validity of this certificate can be verified on request at the following e-mail address: info@kiwacermet.it

This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia.

Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.

Certificate KIP-08345



Issue date	30-07-2026	Replaces	--
PIN	0476DR4719	Report number	2014719
Module	B (Type testing)	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)

EC TYPE-EXAMINATION CERTIFICATE (BED/R813)

Kiwa Cermet Italia, notified body for council Directive 92/42/EC, hereby declares that the Central heating condensing boiler, type(s):

CIAO X 25C C10

Manufacturer

RIELLO S.p.A.
Via Ing. Pilade Riello, 7
37045 Legnago (VR) - Italy

meet the requirements regarding useful efficiencies according to **article 4 of commission regulation (EU) No. 813/2013** and as described in the **Directive 92/42/EEC on efficiency requirements**.

Reference standard:
EN 15502-1:2021+A1:2023,
EN 15502-2-1:2022+A1:2023/AC:2024,
CEN/TS 15502-3-1:2024

This certificate is only valid in combination with the appendix to this certificate, where specific information and/or conditions are given.

Kiwa Cermet Italia S.p.a.
Product Certification and Testing Director
Luigi Rindone

Certificate

KIP-08345

Issue date	30-07-2026	Replaces	--
PIN	0476DR4719	Report number	2014719
Module	B (Type testing)	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:

BERETTA

Specifications:

Model(s):

CIAO X 25C C10

Condensing boiler:	yes
Range rated:	yes
Low-temperature boiler:	no
B1 boiler:	no
Combination heater:	yes

Useful heat output

At rated heat output and high-temperature regime (*)	P ₄	19,3 kW
At 30 % of rated heat output and low-temperature regime (**)	P ₁	6,4 kW

Useful efficiencies (GCV)

At rated heat output and high-temperature regime (*)	η_4	86,6 %
At 30 % of rated heat output and low-temperature regime (**)	η_1	95,1 %

Useful efficiencies (NCV)

At rated heat output and high-temperature regime (*)	η_{100}	96,2 %
At 30 % of rated heat output and low-temperature regime (**)	η_{30}	105,6 %

(*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

(GCV) Calculated values are based on Gross calorific value (reference conditions:15 °C, 1013,25 mbar)

(NCV) Calculated values are based on Net calorific value (reference conditions:15 °C, 1013,25 mbar)

The validity of this certificate can be verified on request at the following e-mail address: info@kiwacermet.it

This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia.

Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.