

# EU TYPE-EXAMINATION CERTIFICATE (MODULE B) REGULATION (EU) 2016/426

This is to certify that the listed appliances have been examined and found to comply with the essential requirements listed in the **Regulation (EU) 2016/426** of the European Parliament and of the council of 9 March 2016 on appliances burning gaseous fuels (Annex I).

To demonstrate full compliance with the Regulation (EU) 2016/426, a "Conformity to Type" Module C2 or D or E or F is required.

**Manufacturer:** Riello S.p.A.

Via Ing. Pilade Riello, 7  
37045 Legnago (VR)  
Italy

**Trademark:** BERETTA

**Product Type:** Central heating combi condensing boiler

**Models:** CIAO 25C f, CIAO 30C f, CIAO X 25C, CIAO X 30C, CIAO X 15R,  
CIAO X 25R, QUADRA X 25C, QUADRA X 25R, QUADRA X 30C,  
BLR 25C, BLR 30C

**Certificate N°:** ITS-2575-GAR-2128897-R9

**PIN:** 2575DM28897

This certificate only relates to those products detailed in the following Test Reports:

**Report Number:** 200028897UDI-GCE-RCE-R14

This certificate cancels and replaces the previous one.

**Certificate first issue date:**

19 May 2025

**Certificate current issue date:**

22 January 2026

**Certificate expiration date:**

01 March 2031

**Michael Albert Gandin**

Certification Manager  
Intertek Italia SpA (NB 2575)



00151

Membro degli Accordi di Mutuo  
Riconoscimento EA, IAF e ILAC

Signatory of EA, IAF and ILAC  
Mutual Recognition Agreements



This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned from the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## PRODUCT DESCRIPTION

<b>PRODUCT TYPE:</b>	Central heating combi condensing boiler
<b>MODELS:</b>	CIAO 25C f, CIAO 30C f, CIAO X 25C, CIAO X 30C, CIAO X 25R <sup>(1)</sup> , QUADRA X 25C, QUADRA X 30C, QUADRA X 25R <sup>(1)</sup> , BLR 25C, BLR 30C  <sup>(1)</sup> = Models designed for heating only but with the possibility of combining a remote storage tank.
<b>STANDARD(S):</b>	EN 15502-1:2021+A1:2023, EN 15502-2-1:2022+A1:2023 /AC:2024, CEN/TS 15502-3-1:2024, UNI-TS 11854
<b>SPECIAL REMARKS:</b>	Minimum ambient temperature > 0°C (-15°C with frost protection kit) Values declared by the Manufacturer
<b>APPLIANCES TYPE:</b>	B <sub>23P</sub> , B <sub>53P</sub> , C <sub>13</sub> , C <sub>33</sub> , C <sub>43</sub> , C <sub>53</sub> , C <sub>63</sub> , C <sub>83</sub> , C <sub>93</sub> , C <sub>13x</sub> , C <sub>33x</sub> , C <sub>43x</sub> , C <sub>53x</sub> , C <sub>63x</sub> , C <sub>83x</sub> , C <sub>93x</sub> , C <sub>(10)3</sub>
<b>COUNTRIES:</b>	According to EN 437:2021
<b>GAS CATEGORIES:</b>	I <sub>2H</sub> , I <sub>2HY20</sub> , I <sub>2HY20M</sub> , I <sub>2E</sub> , I <sub>2EY20</sub> , I <sub>2ELL</sub> , I <sub>2E(S)</sub> , I <sub>2E(R)</sub> , I <sub>2Esi</sub> , I <sub>2Er</sub> , I <sub>2ELwLS</sub> , I <sub>2EY20LwLS</sub> , I <sub>3P</sub> , II <sub>2H3P</sub> , II <sub>2HY203P</sub> , II <sub>2HY20M3P</sub> , II <sub>2E3P</sub> , II <sub>2EY203P</sub> , II <sub>2E(S)3P</sub> , II <sub>2E(R)3P</sub> , II <sub>2Esi3P</sub> , II <sub>2Er3P</sub> , II <sub>2ELL3P</sub> , II <sub>2ELwLS3P</sub> , II <sub>2EY20LwLS3P</sub>

### DETAILS FOR GAS GROUPS, REFERENCE GASES AND SUPPLY PRESSURES:

GROUP	REFERENCE GAS	GROUP	REFERENCE GAS	GROUP	REFERENCE GAS
2H	G20 – 20 mbar	2LL	G25 – 20 mbar	3P	G31 – 30 mbar
2H	G20 – 25 mbar	2Lw	G27 – 20 mbar	3P	G31 – 37 mbar
2E	G20 – 20 mbar	2Ls	G2.350 – 13 mbar	3P	G31 – 50 mbar
2Esi	G20/G25 – 20/25 mbar	2M	G230 – 20 mbar		
2Er	G20/G25 – 20/25 mbar	2HY20	G20Y20 – 20 mbar #		
2E(S)	G20 – 20 mbar	2EY20	G20Y20 – 20 mbar #		
2E(R)	G20 – 20 mbar				

# Suffix Y20 indicates gas group(s) not yet introduced in EN 437 and based on a gas blend of Methan/Hydrogen with max amount of H<sub>2</sub> = 20mol%.

## PRODUCT DESCRIPTION

<b>PRODUCT TYPE:</b>	Central heating combi condensing boiler
<b>MODELS:</b>	<p>CIAO X 15R <sup>(1)</sup></p> <p><sup>(1)</sup> = Models designed for heating only but with the possibility of combining a remote storage tank.</p>
<b>STANDARD(S):</b>	EN 15502-1:2021+A1:2023, EN 15502-2-1:2022+A1:2023 /AC:2024, CEN/TS 15502-3-1:2024, UNI-TS 11854
<b>SPECIAL REMARKS:</b>	Minimum ambient temperature > 0°C (-15°C with frost protection kit) Values declared by the Manufacturer
<b>APPLIANCES TYPE:</b>	B <sub>23P</sub> , B <sub>53P</sub> , C <sub>13</sub> , C <sub>33</sub> , C <sub>43</sub> , C <sub>53</sub> , C <sub>63</sub> , C <sub>83</sub> , C <sub>93</sub> , C <sub>13x</sub> , C <sub>33x</sub> , C <sub>43x</sub> , C <sub>53x</sub> , C <sub>63x</sub> , C <sub>83x</sub> , C <sub>93x</sub> , C <sub>(10)3</sub>
<b>COUNTRIES:</b>	According to EN 437:2021
<b>GAS CATEGORIES:</b>	I <sub>2H</sub> , I <sub>2HY20</sub> , I <sub>2E</sub> , I <sub>2EY20</sub> , I <sub>2ELL</sub> , I <sub>2E(S)</sub> , I <sub>2E(R)</sub> , I <sub>2Esi</sub> , I <sub>2Er</sub> , I <sub>2ELwLS</sub> , I <sub>2EY20LwLS</sub> , I <sub>3P</sub> , II <sub>2H3P</sub> , II <sub>2HY203P</sub> , II <sub>2E3P</sub> , II <sub>2EY203P</sub> , II <sub>2E(S)3P</sub> , II <sub>2E(R)3P</sub> , II <sub>2Esi3P</sub> , II <sub>2Er3P</sub> , II <sub>2ELL3P</sub> , II <sub>2ELwLS3P</sub> , II <sub>2EY20LwLS3P</sub>

### DETAILS FOR GAS GROUPS, REFERENCE GASES AND SUPPLY PRESSURES:

GROUP	REFERENCE GAS	GROUP	REFERENCE GAS	GROUP	REFERENCE GAS
2H	G20 – 20 mbar	2E(S)	G20 – 20 mbar	3P	G31 – 30 mbar
2H	G20 – 25 mbar	2E(R)	G20 – 20 mbar	3P	G31 – 37 mbar
2E	G20 – 20 mbar	2Lw	G27 – 20 mbar	3P	G31 – 50 mbar
2LL	G25 – 20 mbar	2Ls	G2.350 – 13 mbar		
2Esi	G20/G25 – 20/25 mbar	2HY20	G20Y20 – 20 mbar #		
2Er	G20/G25 – 20/25 mbar	2EY20	G20Y20 – 20 mbar #		

# Suffix Y20 indicates gas group(s) not yet introduced in EN 437 and based on a gas blend of Methan/Hydrogen with max amount of H<sub>2</sub> = 20mol%.

## REVISION AND COMMENTS

DD/MM/YYYY	AMENDED BY	PROJECT NO.	REPORT NO.	REASON FOR REVISION
01/03/2021	S. Zornio	28897	200028897UDI-GCE-RCE	R0: First issue
27/07/2021	G. Baiocco	29504	200028897UDI-GCE-RCE-R1	R1: Added gas groups: M, Lw, Ls, Y20 and appliance type C <sub>(10)</sub> and added models
28/10/2021	M.A. Gandin	31649	200028897UDI-GCE-RCE-R2	R2: Introduction of new model CIAO X 15R
28/07/2022	M.A. Gandin	33875	200028897UDI-GCE-RCE-R7	R3: Introduction of product codes for models CIAO X 25C and CIAO X 30C with alternModification on ative fan motor
23/01/2023	M.A. Gandin	35443	200028897UDI-GCE-RCE-R8	R4: Verification according to EN 15502-1:2021 and introduction of new gas categories
02/02/2023	M.A. Gandin	35443	200028897UDI-GCE-RCE-R8	R5: Typo correction
29/02/2024	M.A. Gandin	40036	200028897UDI-GCE-RCE-R9	R6: Standard updating and introduction of new models BLR 25C and BLR 30C
19/04/2024	M.A. Gandin	40750	200028897UDI-GCE-RCE-R10	R7: Introduction of alternative components
19/05/2025	M.A. Gandin	44236	200028897UDI-GCE-RCE-R12	R8: Introduction of an alternative component and standards updating
22/01/2026	M.A. Gandin	45930	200028897UDI-GCE-RCE-R14	R9: Modification of appliances construction

# EU TYPE-EXAMINATION CERTIFICATE (MODULE B) DIRECTIVE 92/42/EEC

This is to certify that, with reference to the Council **Directive 92/42/EEC** of 21 May 1992 on efficiency requirements for new hot-water boilers fired with liquid or gaseous fuels and according to article 4 of commission regulation (EU) No. 813/2013, the appliances listed have achieved the full and part load efficiencies written on Annex 1.

To demonstrate full compliance with the Directive 92/42/EEC, a “Conformity to type” Module C or D or E is required.

**Manufacturer:** Riello S.p.A.

Via Ing. Pilade Riello, 7  
37045 Legnago (VR)  
Italy

**Trademark:** BERETTA

**Product Type:** Central heating combi condensing boiler

**Models:** CIAO 25C f, CIAO 30C f, CIAO X 25C, CIAO X 30C, CIAO X 15R,  
CIAO X 25R, QUADRA X 25C, QUADRA X 25R, QUADRA X 30C,  
BLR 25C, BLR 30C

**Certificate N°:** ITS-2575-BED-2128897-R4

**PIN:** 2575DM28897

**Standard(s):** EN 15502-1:2021+A1:2023,  
EN 15502-2-1:2022+A1:2023/AC:2024

This certificate only relates to those products detailed in the following Test Reports:

**Report Number:** 200028897UDI-GCE-RCE-R12

**Certificate Issue date:**

19 May 2025

**Certificate Expiry date:**

28 February 2031

**Michael Albert Gandin**

Certification Manager  
Intertek Italia SpA (NB 2575)



PRD N° 277B

Membro degli Accordi di Mutuo  
Riconoscimento EA, IAF e ILAC

Signatory of EA, IAF and ILAC  
Mutual Recognition Agreements



This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## ANNEX 1

Models:				
	CIAO X 15R	CIAO X 25C QUADRA X 25C BLR 25C	CIAO X 25R QUADRA X 25R	CIAO X 30C QUADRA X 30C BLR 30C
$\eta_{100}$	96,7 %	97,0 %	97,0 %	97,3 %
$\eta_{30}$	109,6 %	109,3 %	109,3 %	109,0 %
$\eta_4$	87,1 %	87,3 %	87,3 %	87,6 %
$\eta_1$	98,7 %	98,5 %	98,5 %	98,2 %
$P_4$	14,5 kW	19,4 kW	19,4 kW	24,4 kW
$P_1$	4,9 kW	6,5 kW	6,5 kW	8,2 kW
C.Heater	No <sup>(1)</sup>	Yes	No <sup>(1)</sup>	Yes
B <sub>1</sub> Boiler	No	No	No	No
Type of boiler:	Condensing	Condensing	Condensing	Condensing
Range Rated?	No	Yes	Yes	Yes
<sup>(1)</sup> models designed for heating only but with the possibility of combining a remote storage tank (the boiler does not have the sanitary circuit but keeps the three-way valve and the connections for the remote storage tank).				

Note:  $\eta_{100}$  = At rated heat output and high-temperature regime - NCV (\*) - EN 15502-1:2021, clause 9.4.3: "the useful efficiency in % at nominal heat input  $Q_n$  or for range rated boilers at the arithmetic mean of the maximum and minimum heat input  $Q_a$ "  
 $\eta_{30}$  = At 30 % of rated heat output and low-temperature regime - NCV (\*\*) - EN 15052-1:2021, clause 9.4.3: "the useful efficiency in % at 30 % of the nominal heat input  $Q_n$  or for range rated boilers at 30 % of the arithmetic mean of the maximum and minimum heat input  $Q_a$ "  
 $\eta_4$  = At rated heat output and high-temperature regime (\*)  
 $\eta_1$  = At 30 % of rated heat output and low-temperature regime (\*\*)  
 $P_4$  = At rated heat output and high-temperature regime (\*)  
 $P_1$  = At 30 % of rated heat output and low-temperature regime (\*\*)  
 C.Heater = Combination Heater (Yes = with domestic hot water production / No = Heating system only)  
 B1 Boiler = B1 according CEN/TR 1749:2014  
 Type of boiler: "Condensing Boiler" or "Low Temperature Boiler" or Other Boiler"

(\*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(\*\*) Low temp. means for condensing boilers 30 °C, for low-temp. boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

## REVISION AND COMMENTS

DD/MM/YYYY	AMENDED BY	PRJ NO.	REPORT NO.	REASON FOR REVISION
01/03/2021	S. Zornio	28897	200028897UDI-GCE-RCE	R0: First issue
27/07/2021	G. Baiocco	29504	200028897UDI-GCE-RCE-R1	R1: added new models
28/10/2021	M.A. Gandin	31649	200028897UDI-GCE-RCE-R2	R2 Introduction of new model CIAO X 15R
29/02/2024	M.A. Gandin	40036	200028897UDI-GCE-RCE-R9	R3: Introduction of new models BLR 25C and BLR 30C
19/05/2025	M.A. Gandin	44236	200028897UDI-GCE-RCE-R12	R4: Typo correction