

Number	KIP-16681/G	Replaces	KIP-16585/G
Issue date	04-11-2020	Contract number	I 7230
Due date	03-11-2030	Scope	(EU) 2016/426 (9 March 2016)
Report number	2003754/4	Module	B (Type testing)
PIN	0476CU3754		

EU TYPE-EXAMINATION CERTIFICATE (GAR)

Kiwa Cermet Italia declares that the central heating condensing boiler, type(s):

**MYNUTE X 20R p, MYNUTE X 25C p, MYNUTE X 30C p, MYNUTE X 30R p,
MYNUTE X 35C p**

Manufacturer

Riello S.p.A.
Via Ing. Pilade Riello, 7
37045 Legnago (VR) - Italy

Meet the essential requirements as described in the
Regulation (EU) 2016/426 relating to appliances burning gaseous fuels.

Reference standard: EN 15502-1:2012+A1:2015, EN 15502-2-1:2012+A1:2016

This certificate is only valid in combination with the appendix to this certificate, where specific information and/or conditions are given.

CERTIFICATE

Kiwa Cermet Italia S.p.A.
Società con socio unico, soggetta all'attività di
direzione e coordinamento di Kiwa Italia
Holding Srl

Via Cadriano, 23
40057 Granarolo dell'Emilia (BO)
Unità locale

Via Treviso 32/34
31020 San Vendemiano (TV)

Tel +39. 0438 411755

Fax +39.0438 22428

E-mail: info@kiwacermet.it

www.kiwa.it

www.kiwacermet.it

GASTEC

Chief Operating Officer
Giampiero Belcredi



Number KIP-16681/G **Page** 1 of 2
Issue date 04-11-2020 **Scope** (EU) 2016/426 (9 March 2016)
Due date 03-11-2030 **Module** B (Type testing)
Report number 2003754/4
PIN 0476CU3754

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (GAR)

Brand name:
BERETTA

Model name	Appliance types	Heat Input (Hi)	
		CH Max – Min (kW)	DHW Max – Min (kW)
MYNUTE X 20R p	B _{23P} , B _{53P} , C ₁₃ , C ₃₃ , C ₄₃ , C ₅₃ , C ₆₃ , C ₈₃ , C ₉₃ , C ₍₁₀₎ , C ₍₁₁₎ , C _{13X} , C _{33X} , C _{43X} , C _{53X} , C _{63X} , C _{83X} , C _{93X}	20,0 – 3,6 5,0 ^{(2) (3)}	⁽¹⁾ 20,0 – 3,6 5,0 ^{(2) (3)}
MYNUTE X 25C p		20,0 – 3,6 5,0 ^{(2) (3)}	25,0 – 3,6 5,0 ^{(2) (3)}
MYNUTE X 30C p		25,0 – 4,9 7,0 ⁽²⁾	30,0 – 4,9 7,0 ⁽²⁾
MYNUTE X 30R p		30,0 – 4,9 7,0 ⁽²⁾	⁽¹⁾ 34,6 – 4,9 7,0 ⁽²⁾
MYNUTE X 35C p		30,0 – 4,9 7,0 ⁽²⁾	34,6 – 4,9 7,0 ⁽²⁾

⁽¹⁾ The boiler can be connected to an external tank for the domestic hot water production

⁽²⁾ minimum declared for the gas category P

⁽³⁾ minimum declared for the gas category M

Countries:

AL, AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MK, MT, NO, NL, PL, PT, RO, SE, SI, SK, TR

Number KIP-16681/G **Page** 2 of 2
Issue date 04-11-2020 **Scope** (EU) 2016/426 (9 March 2016)
Due date 03-11-2030 **Module** B (Type testing)
Report number 2003754/4
PIN 0476CU3754

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (GAR)

Models:

MYNUTE X 30C p, MYNUTE X 30R p, MYNUTE X 35C p

Gas groups:

Group	mbar
E	20
H	20;25

Group	mbar
Lw	20
Ls	13

Group	mbar
P	30;37;50

Models:

MYNUTE X 25C p, MYNUTE X 20R p

Gas groups:

Group	mbar
E	20
H	20;25

Group	mbar
P	30;37;50
M	20


Group	mbar
Lw	20
Ls	13

The above gas groups can be combined according to the standard EN437:2018 and national situation of countries.

Remarks: –

The validity of this certificate can be verified on request at the following e-mail address: info@kiwacermet.it

This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia. Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.



Number	KIP-16616/E	Replaces	KIP-16344/E
Issue date	15-07-2020	Contract number	I 7230
Report number	2003754/3	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
PIN	0476CU3754	Module	B (Type testing)

EC TYPE-EXAMINATION CERTIFICATE (BED/R813)

Kiwa Cermet Italia, notified body for council Directive 92/42/EC, hereby declares that the Central heating condensing boilers, type(s):

**MYNUTE X 25C p, MYNUTE X 20R p, MYNUTE X 30C p,
MYNUTE X 30R p, MYNUTE X 35C p**

Manufacturer

RIELLO S.p.A.
Via Ing. Pilade Riello, 7
37045 Legnago (VR) - Italy

meet the requirements regarding useful efficiencies according to **article 4 of commission regulation (EU) No. 813/2013** and as described in the **Directive 92/42/EEC on efficiency requirements**.

Reference standard: EN 15502-1:2012+A1:2015 and EN 15502-2-1:2012+A1:2016

This certificate is only valid in combination with the appendix to this certificate, where specific information and/or conditions are given.

Kiwa Cermet Italia S.p.A.
Società con socio unico, soggetta all'attività di
direzione e coordinamento di Kiwa Italia
Holding Srl

Via Cadriano, 23
40057 Granarolo dell'Emilia (BO)
Unità locale

Via Treviso 32/34
31020 San Vendemiano (TV)

Tel +39. 0438 411755

Fax +39.0438 22428

E-mail: info@kiwacermet.it

www.kiwa.it

www.kiwacermet.it

GASTEC

Chief Operating Officer
Giampiero Belcredi



Number	KIP-16616/E	Page	1 of 5
Issue date	15-07-2020	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
Report number	2003754/3	Module	B (Type testing)
PIN	0476CU3754		

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:
BERETTA

Specifications:
Model:
MYNUTE X 25C p

Condensing boiler:	yes
Range rated:	yes
Low-temperature boiler:	no
B1 boiler:	no
Combination heater:	yes

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P ₄	19,5	kW
At 30 % of rated heat output and low-temperature regime (**)	P ₁	6,5	kW
Useful efficiencies			
At rated heat output and high-temperature regime (*)	η ₄	87,1	%
At 30 % of rated heat output and low-temperature regime (**)	η ₁	96,7	%

- (*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.
- (**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

Calculated values are based on gross calorific value (reference conditions:15 °C, 1013,25 mbar)

The validity of this certificate can be verified on request at the following e-mail address: info@kiwacermet.it
This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia.
Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.

Number	KIP-16616/E	Page	2 of 5
Issue date	15-07-2020	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
Report number	2003754/3	Module	B (Type testing)
PIN	0476CU3754		

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:
BERETTA

Specifications:
Model:
MYNUTE X 20R p

Condensing boiler:	yes
Range rated:	yes
Low-temperature boiler:	no
B1 boiler:	no
Combination heater:	no ⁽¹⁾

⁽¹⁾ The boiler can be connected to an external tank for domestic hot water production.

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P ₄	19,5	kW
At 30 % of rated heat output and low-temperature regime (**)	P ₁	6,5	kW
Useful efficiencies			
At rated heat output and high-temperature regime (*)	η ₄	87,1	%
At 30 % of rated heat output and low-temperature regime (**)	η ₁	96,7	%

- (*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.
- (**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

Calculated values are based on gross calorific value (reference conditions: 15 °C, 1013,25 mbar)

The validity of this certificate can be verified on request at the following e-mail address: info@kiwacermet.it
This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia.
Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.

Number	KIP-16616/E	Page	3 of 5
Issue date	15-07-2020	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
Report number	2003754/3	Module	B (Type testing)
PIN	0476CU3754		

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:
BERETTA

Specifications:
Model:
MYNUTE X 30C p

Condensing boiler:	yes
Range rated:	yes
Low-temperature boiler:	no
B1 boiler:	no
Combination heater:	yes

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P ₄	24,4	kW
At 30 % of rated heat output and low-temperature regime (**)	P ₁	8,1	kW
Useful efficiencies			
At rated heat output and high-temperature regime (*)	η ₄	87,6	%
At 30 % of rated heat output and low-temperature regime (**)	η ₁	96,5	%

- (*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.
- (**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

Calculated values are based on gross calorific value (reference conditions:15 °C, 1013,25 mbar)

The validity of this certificate can be verified on request at the following e-mail address: info@kiwacermet.it
This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia.
Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.

Number	KIP-16616/E	Page	4 of 5
Issue date	15-07-2020	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
Report number	2003754/3	Module	B (Type testing)
PIN	0476CU3754		

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:
BERETTA

Specifications:
Model:
MYNUTE X 30R p

Condensing boiler:	yes
Range rated:	yes
Low-temperature boiler:	no
B1 boiler:	no
Combination heater:	no ⁽¹⁾

⁽¹⁾ The boiler can be connected to an external tank for domestic hot water production.

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P ₄	29,3	kW
At 30 % of rated heat output and low-temperature regime (**)	P ₁	9,7	kW
Useful efficiencies			
At rated heat output and high-temperature regime (*)	η ₄	87,6	%
At 30 % of rated heat output and low-temperature regime (**)	η ₁	96,5	%

- (*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.
- (**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

Calculated values are based on gross calorific value (reference conditions: 15 °C, 1013,25 mbar)

The validity of this certificate can be verified on request at the following e-mail address: info@kiwacermet.it
This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia.
Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.

Number	KIP-16616/E	Page	5 of 5
Issue date	15-07-2020	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
Report number	2003754/3	Module	B (Type testing)
PIN	0476CU3754		

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:
BERETTA

Specifications:
Model:
MYNUTE X 35C p

Condensing boiler:	yes
Range rated:	yes
Low-temperature boiler:	no
B1 boiler:	no
Combination heater:	yes

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P ₄	29,3	kW
At 30 % of rated heat output and low-temperature regime (**)	P ₁	9,7	kW
Useful efficiencies			
At rated heat output and high-temperature regime (*)	η ₄	87,6	%
At 30 % of rated heat output and low-temperature regime (**)	η ₁	96,5	%

- (*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.
- (**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

Calculated values are based on gross calorific value (reference conditions:15 °C, 1013,25 mbar)

The validity of this certificate can be verified on request at the following e-mail address: info@kiwacermet.it
This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia.
Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.